



1. TRENCH WALLS TO BE SUPPORTED AS REQUIRED BY OSHA.
2. TRENCH BACKFILL SHALL CONTAIN NO ROCKS/STONES LARGER THAN 4" IN DIAMETER.
3. GEO-TEXTILE FABRIC TO COVER GRANULAR BEDDING MATERIAL, NO. 67.
4. AWWA C900 SANITARY SEWER WYES SHALL BE DR18 FOR NON-PRESSURE SEWER APPLICATION.

<p>DATE 10/25/2019</p>	<p>VALLEY SANITATION DISTRICT</p>	<p>EXPANSIVE SOIL BEDDING DETAIL</p>
<p>DRAWING D.4S</p>		